

Smoke and Heat Control Systems “Actulux MCP”, “Actulux iMCP”

Issued to

Actulux A/S

Porsborgparken 35, DK-9530 Støvring, Denmark

Product name

Actulux MCP, Actulux iMCP

Product description

Smoke and heat control systems: Manual Call Points, type B. Software version 1.03.1.

Certificate

The products described in this certificate have been type-examined by RISE and found to fulfil the applicable requirements set out in standard ISO 21927-9:2012. (Clauses: 5.1.2.5, 5.3.1, 5.3.2, 5.3.3, 5.3.4, 8.4 and 12). Basis for this certificate is test report no. P118276.DP01.A02, issued by RISE Research Institutes of Sweden AB, Unit: *Electrification and Reliability - Safe Control Systems*.

Specification:

Manual call points, type B. Colour: deep orange (RAL 2011). For indoor use.

Marking

Each product that conforms in all respects with the original item type-examined may display the text 'Type examined by RISE'. When this marking is applied the marking shall also contain the information required by the actual standard, the number of this certificate and the serial number or equivalent of the item.

Validity

This certificate is valid until not later than 2029-08-27. The validity of this certificate can be verified by RISE.

Miscellaneous

Other terms and conditions are set out in RISE certification rules for type-examination, SPCR 123.

A handwritten signature in blue ink, appearing to read 'Martin Tillander'.

Martin Tillander

Certificate C901170 | issue 1 | 2024-08-27

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

+46 10 516 50 00 | certifiering@ri.se | www.ri.se

1279285

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

Page 1 (1)